CETEC Pty Ltd ABN 44 006 873 687
Melbourne | Sydney | Brisbane | Perth | London | San Francisco

VOC Content Test Certificate

Monday, 7th September 2026

Supplier: RLA Polymers Pty Ltd (215 COLCHESTER RD, KILSYTH, VIC, 3137, Australia).

Product Name: Karndean Mega-Base MT

Date Tested: 27th August 2026 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-25 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification **Green Building Council of Australia** **Green Star Buildings V1 Revision C** **Exposure to Toxins Credit 13**	**Karndean Mega-Base MT**
General Purpose Adhesives and Sealants Limit: 50 grams per litre	**1 gram per litre as VOC content per material**
Meets GBCA VOC Content Requirement	**Yes**

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 7/09/2026 **Expiry date: 7/09/2031** **P26080098**