CETEC Pty Ltd ABN 44 006 873 687
Melbourne | Sydney | Brisbane | Perth | London | San Francisco

VOC Content Test Certificate

Tuesday 11th August 2026

Supplier: RLA POLYMER PTY LTD (215 Colchester Road, Kilsyth, VIC, 3137, AUSTRALIA).

Product name: Karndean Mega-Bond MT Adhesive

Date Tested: 10th August 2026 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960-25 test method is referred in accordance with the laboratory testing guidance from Green Building Council of Australia.

Test Data:

Specification **Green Building Council of Australia** **Green Star Design & As Built V1.3-13.1.1B** **Green Star Interiors V1.3-12.1.1B**	**Karndean Mega-Bond MT Adhesive**
General Purpose Adhesive and Sealant Limit: 50 grams per litre	**23 grams per litre as VOC content per material**
We hereby certify Karndean Mega-Bond MT Adhesive is below the VOC Content limits of chosen category specified by Green Star Design, Green Building Council of Australia	

Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant

Dr. Tuan Duong
PhD, BE (Chemical Engineer)
Senior Consultant

Travis Hale
BSc (Biotechnology)
Senior Consultant

Issue Date: 11/08/2025 **Expiry date: 11/08/2031** **P26060001**