SCS Global Services *does hereby certify that an independent assessment has been conducted on behalf of:*

Karndean Designflooring

Crab Apple Way, Vale Park, Evesham, Worcestershire WR11-1GP, United Kingdom

For the following product(s):

Flooring Adhesives:
K-Spray

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-105 Version 4.2 – 2023

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring. Also, conforms to the SCAQMD Rule 1168 - Adhesive and Sealants (October 2017).

Standard Product Application Amount: 100.0 g/m2

Measured Concentration of Total Volatile Organic Compounds (TVOC): 0.5 mg/m3 or less in compliance with CDPH/EHLB Standard Method v1.2-2017)

Methylene Chloride and Perchloroethylene are not intentionally added to certified products.

Registration # SCS-FS-04067

Valid from: October 01, 2026 to September 30, 2027

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, http://www.scsglobalservices.com/certified-green-products-guide.

Diana Kirsanova Phillips, Chief of Staff to the CEO / Chief Assurance Officer
SCS Global Services